PSB Singapore

# CERTIFICATE OF CONFORMITY

## No. CLS1B 081408 0036 Rev. 00

Initial No. -

| | |
|---|---|
| **Certificate Holder:** | **CLF Shutters Asia Pte Ltd**<br>138 Genting Lane<br>Singapore 349582<br>SINGAPORE |
| **Certification Mark:** | TÜV SÜD PSB |
| **Product:** | Fire Curtains |
| **Brand Name:** | CLF Shutters |
| **Model(s):** | CLF-F4I2 |
| **Product Details:** | Integrity: 240 mins ; Insulation: 120 mins<br>Maximum size: 13m(W) x 8m(H)<br>A double layer insulated fabric curtain assembly |
| **Standard(s):** | SS 489:2015 Cl 4.5 (closing speed) & Cl 5 |
| **Country of Origin:** | Singapore |
| **Test Report(s):** | TÜV SÜD PSB No. 7191188526-MEC18-RAH<br>EWFA Assessment No. FAS180027.1 |
| **Valid until:** | 2023-09-30 |

Products listed under Class 1B must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.



**Issued on:** 2018-11-16

Vice-President (Certification Department)
TÜV SÜD PSB

Accredited Certification Body
SAC
PD-2002-01

This Certificate is part of a full Report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at www.tuv.sud-psb.sg

TÜV SÜD PSB Pte Ltd • 1 Science Park Drive • Singapore 118221

TÜV®

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT
TÜV SÜD