



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS1B 17 01 81408 025

Certificate Holder: CLF Shutters Asia Pte Ltd
138 Genting Lane
Singapore 349582
SINGAPORE

Certification Mark:



Product: Fire Shutters

Brand Name: CLF Shutters

Model(s): GFI33

Product Details: Integrity: 180 mins ; Insulation: 180 mins
Maximum size: 13m(W) x 8m(H)
A vertical roller shutter of double layer insulated fabric, with the outer layer (unexposed face) clad with a single layer of steel slates

Standard(s): SS 489:2001 CI 3.5 & 4

Country of Origin: Singapore

Test Report(s): See CoC Appendix (1pg)

Issued on: 2017-01-12

Valid until: 2017-11-14

Products listed under Class 1B must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Page 1 of 2

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at www.tuv-sud-psb.sg


Vice-President (Certification Department)
TÜV SÜD PSB





PSB Singapore

PRODUCT LISTING SCHEME APPENDIX

TO CERTIFICATE OF CONFORMITY NUMBER: CLS1B 17 01 81408 025

Date of Issue : 2017-01-12

Issued To : CLF Shutters Asia Pte Ltd
138 Genting Lane
Singapore 349582
SINGAPORE

Test Report(s) : TÜV SÜD PSB No. 7191136736-MEC16-LJH
EWA Assessment No. 33599100

A handwritten signature in blue ink, appearing to read 'Chang'.

Vice President (Certification Department)
TÜV SÜD PSB