



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS1B 18 06 81408 033

Initial No. CLS1B 17 11 81408 029

Certificate Holder: CLF Shutters Asia Pte Ltd
138 Genting Lane
Singapore 349582
SINGAPORE

Certification Mark:

TÜV SÜD PSB

Product: Fire Shutters

Brand Name: 3-circle

Model(s): CLF-FRS-04

Product Details: Integrity: 240 mins
Maximum size: 12.5m(W) x 4.5m(H)
An uninsulated single layer steel slats vertical roller shutter with concealed side guides

Standard(s): SS 489:2015 CI 4.5 (closing speed) & CI 5

Country of Origin: Singapore

Test Report(s): See CoC Appendix (1pg)

Issued on: 2018-06-06

Valid until: 2022-12-10

Products listed under Class 1B must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Page 1 of 2

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at www.tuv-sud-psb.sg


Vice-President (Certification Department)
TÜV SÜD PSB



Cert No: PD-2002-01



PSB Singapore

PRODUCT LISTING SCHEME APPENDIX

TO CERTIFICATE OF CONFORMITY NUMBER: CLS1B 18 06 81408 033

Date of Issue : 2018-06-06

Issued To : CLF Shutters Asia Pte Ltd
138 Genting Lane
Singapore 349582
SINGAPORE

Test Report(s) : TÜV SÜD PSB No. 7191172953-MEC17-KKC
EWFA Assessment No. 53691800.1



Vice President (Certification Department)
TÜV SÜD PSB